

Module 2 : Convection

Lecture 20 : Heat Transfer Enhancement Evaluation in Roughened Heat Exchanger Tubes

Objectives

In this class:


- Methodologies for evaluation of the performance of heat transfer enhancement devices in heat exchanger tubes of tube in tube type
- Material from "Application of Rough Surfaces to Heat Exchanger Design" R.L. Webb, R.L. & Eckert, E.R.G" International Journal of Heat and Mass Transfer pg. 1647, 1972

Rough Surface Heat Exchanger tubes-1

- The analysis in Class 19 was one where a heat flux was assumed to have been supplied to the pipe. Only the internal heat transfer coefficients were considered.
- Now consider a situation where outer wall of the tube is exposed to a fluid that transfers heat to the inner tube.
- Only the inner tube is assumed to have been roughened.

Rough Surface Heat Exchanger tubes-2

- There is now an outer heat transfer coefficient also.



Rough Surface Heat Exchanger tubes-3

- Let:
- A_{os}, A_{or}, A_s, A_r = outer/inner surface of smooth/rough inner tube respectively.
- h_o, h_s, h_r = heat transfer coefficients for outer tube, inner smooth/rough tube.
- Notice that even though A_s and A_r are not necessarily equal:

$$\frac{A_s}{A_{os}} = \frac{A_r}{A_{or}} = 1$$

Rough Surface Heat Exchanger tubes-4

- In this case the resistance to heat transfer due to the outer tube also needs to be considered and using a 1D analogy:

$$\frac{1}{UA} = \frac{1}{h_s A_s} + \frac{1}{h_o A_{os}} = \frac{1}{h_s A_s} \left[1 + \frac{h_s A_s}{h_o A_{os}} \right] \quad (20.1)$$

- U is the overall heat transfer coefficient. An equation like eqnⁿ (20.1) can also be written for the rough tube.
- Assume that the outer tube is not modified for enhancement and h_o remains constant

Rough Surface Heat Exchanger tubes-5

- The smooth and rough heat exchangers need to be compared

$$\frac{1}{U_s A_s} = \frac{1}{h_s A_s} [1+r]; \quad (20.2)$$

$$\frac{1}{U_r A_r} = \frac{1}{h_r A_r} \left(1+r \frac{h_r}{h_s} \right) \quad (20.4)$$

$$r = \frac{h_s A_s}{h_0 A_{0s}} = \frac{h_s}{h_0}$$

- Now we can analyze in a manner similar to the previous situation.

Rough Surface Heat Exchanger tubes-6

- Conductance ratio therefore becomes:

$$\frac{k_r}{k_s} = \frac{U_r A_r}{U_s A_s} = \frac{A_r}{A_s} \frac{(1+r)}{(h_s/h_r + r)} \quad (20.5)$$

- Heat transfer coefficient ratio for the inner smooth and rough situations is:

$$\frac{h_r}{h_s} = \frac{h_r \rho c_p u_r}{\rho c_p u_r} \frac{\rho c_p u_s}{h_s \rho c_p u_s} = \frac{St_r}{St_s} \frac{1}{g^*}$$

where $\frac{\rho u_r}{\rho u_s} = \frac{1}{g^*}$ (20.6)

Rough Surface Heat Exchanger tubes-7

- Therefore

$$\frac{k_r}{k_s} = \frac{A_r}{A_s} \left[\frac{1+r}{g^* \frac{St_s}{St_r} + r} \right] \quad (20.7)$$

- Note that for $r = 0$ equⁿs (20.7) and (19.2) are identical; i.e. conductance in the previous case was infinite for the outer wall – this is alright since outer wall flux was specified i.e. resistance on outer wall is zero.
- Do the same manipulations as in the previous case and obtain the core equation.

Rough Surface Heat Exchanger tubes-8

- The pumping power equation is the same as derived previously (i.e. equⁿ (19.8)):

$$\frac{P_r}{P_s} = \frac{f_r A_r}{f_s A_s} \left(\frac{1}{g^*} \right)^3 \quad (20.8)$$

- Substitute equⁿ (20.8) in equⁿ (20.7) to get:

$$\frac{k_r}{k_s} = \frac{A_r}{A_s} \left[\frac{(1+r)}{\frac{(f_r/f_s)^{1/3} (A_r/A_s) St_s}{(P_r/P_s)^{1/3}} + r} \right] \quad (20.9)$$

Rough Surface Heat Exchanger tubes-9

- Equⁿ (20.9) is further simplified to yield

$$\begin{aligned} \frac{k_r}{k_s} \left(\frac{f_r}{f_s} \right)^{1/3} \left(\frac{A_r}{A_s} \right)^{1/3} \left(\frac{P_s}{P_r} \right)^{1/3} \frac{St_s}{St_r} + r \frac{k}{k_s} &= (1+r) \frac{A_r}{A_s} \\ \frac{k_r}{k_s} \left(\frac{A_r}{A_s} \right)^{1/3} &= \frac{(1+r)A_r/A_s - rk_r/k_s}{\frac{St_s}{St_r} \left(\frac{P_s}{P_r} \right)^{1/3} \left(\frac{f_r}{f_s} \right)^{1/3}} \\ \Rightarrow \frac{\frac{k_r}{k_s} \left(\frac{A_r}{A_s} \right)^{1/3}}{\left(\frac{P_s}{P_r} \right)^{1/3} [(1+r)A_r/A_s - rk_r/k_s]} &= \frac{\left(\frac{St_r}{St_s} \right)}{\left(\frac{f_r}{f_s} \right)^{1/3}} \end{aligned} \quad (20.10)$$

Rough Surface Heat Exchanger tubes-10 Constant Pumping Power, Conductance

- Again do the same manipulations for the three cases. First consider $P/P_s = k/k_s = 1$. Start with equⁿ (20.5) and simplify:

$$\frac{k_r}{k_s} = 1 = \frac{A_r}{A_s} \frac{(1+r)}{g^* \left(\frac{St_s}{St_r} \right) + r} \quad (20.11)$$

$$\Rightarrow \frac{A_r}{A_s} = \frac{g^* St_s / St_r + r}{1+r} \quad (20.12)$$

- Start with equⁿ (20.8) to get:

$$\frac{P_r}{P_s} = 1 = \frac{f_r}{f_s} \frac{A_r}{A_s} \frac{1}{g^{*3}}$$

Rough Surface heat Transfer: tubes-11 Constant Pumping Power, Conductance

- Use $k/k_s = 1 = P/P_s = 1$ in equⁿ (20.10) and use equⁿ (20.13) to get

$$\begin{aligned} \frac{\left(\frac{A_r}{A_s} \right)^{1/3}}{\frac{1}{g^{*2}} \frac{A_r}{A_s} \left[(1+r)g^{*2} - r \frac{f_r}{f_s} \frac{1}{g^*} \right]} &= \frac{St_r / St_s}{(f_r / f_s)^{1/3}} \\ \Rightarrow \frac{\left(A_s / A_r \right)^{2/3} g^{*2}}{(1+r)g^{*2} - r \frac{f_r}{f_s} \frac{1}{g^*}} &= \frac{St_r / St_s}{(f_r / f_s)^{1/3}} \\ \Rightarrow \frac{\left[(f_r / f_s)^{2/3} 1 / g^{*2} \right] g^{*2}}{(1+r)g^{*2} - r \frac{f_r}{f_s} \frac{1}{g^*}} &= \frac{St_r / St_s}{(f_r / f_s)^{1/3}} \end{aligned} \quad (20.14)$$

Rough Surface Heat Exchanger tubes-12
Constant Pumping Power, Conductance

- Equⁿ (20.14) is simplified to yield the final expression:

$$\frac{f_r / St_r}{f_s / St_s} = g^{*2} (1+r) - \frac{r(f_r / f_s)}{g^*} \quad (20.15)$$

- Use equⁿ (20.15) to obtain g*. Now use this in the A/As expression i.e. equⁿ (20.12), to verify whether it is less than unity or not.

Rough Surface heat Transfer: tubes-13
Constant Pumping Power, Area

- Next case P/Ps = 1, A/As = 1. Use equⁿ (20.13) to yield:

$$g^* = (f_r / f_s)^{1/3}$$

- Substitute in equⁿ (20.11) to yield

$$\frac{k_r}{k_s} = \frac{1+r}{(f_r / f_s)^{1/3} (St_s / St_r) + r} \quad (20.16)$$

- Note that this is the same as equⁿ (19.13) for r = 0 in equⁿ (20.16).

Rough Surface heat Transfer: tubes-14
Constant Area, Conductance

- Last case k/ks=1, A/As=1
- Use equⁿ (20.7)

$$1 = \frac{1+r}{(g^* St_s / St_r + r)} \Rightarrow g^* = St_r / St_s \quad (20.17)$$

- Use equⁿ (20.8) to get:

$$g^* = \frac{(f_r / f_s)^{1/3}}{(P_r / P_s)^{1/3}} \quad (20.18)$$

- Equate equⁿs (20.17) and (20.18) to get:

$$\Rightarrow \frac{P_r}{P_s} = \frac{f_r / f_s}{(St_r / St_s)^3} \quad (20.19)$$

Recap

In this class:

- Methodologies for evaluation of the performance of heat transfer enhancement devices in heat exchanger tubes of tube in tube type
- Material from "Application of Rough Surfaces to Heat Exchanger Design" R.L. Webb, R.L. & Eckert, E.R.G" International Journal of Heat and Mass Transfer pg. 1647, 1972